

OSA 156RKSH & OSA 156RKTH

Reverse Cycle R410A Split System Outdoor Unit

Installation & Maintenance

GENERAL

OSA 156RKS – single phase version

OSA 156RKT – three phase version

This OSA 156RK Outdoor Unit must be installed in accordance with all national and local safety codes.

Options

1. Vertical discharge grille.
2. Wall mounting brackets.
3. Anti-vibration mounts (rubber).
4. Drain connection adaptors - right angle.

INSTALLATION

Positioning

Refer to dimension diagram below for minimum clearances. Position the unit so that prevailing winds do not blow onto the exhaust to slow the fan, and one unit does not exhaust toward the inlet of another unit. The optional vertical discharge grille can be used to deflect prevailing winds and reduce clearances.

Mount either free standing or on a wall using the optional mounting brackets available.

Free Standing :

Fasten the unit down to a firm flat horizontal base using the four holes provided in the mounting rails.

When the unit is being installed on a roof it is recommended that the unit is installed on a substantial structure with vibration isolating springs or rubber mounts (optional extra) beneath the unit. These items are not supplied with the unit.

Wall Mounting Option:

Complete wall mounting instructions are supplied with the optional wall mounting kit.

Drain

Four drain holes are provided in the base. Three plastic bungs are supplied (loose) should you want to direct the condensate and/or rain water to one of the holes provided. Drain connection adaptors (25/13) are available as an optional extra.

REFRIGERATION PIPING

General

The OSA 156 is shipped with a refrigerant charge sufficient for a 10 m line length. The matched indoor unit is shipped with a holding charge of nitrogen. OSA 156 units have shut-off service valves and swaged assemblies. Two loose pipe extensions are supplied to enable a choice of exit – side or rear; both require brazing.

Recommended Pipe Sizes

Suction pipe : 22 mm OD
Liquid pipe : 13 mm OD

Line Lengths


The standard unit allows for a line length up to 30 m. For line lengths between 30 m and 60 m, refer to **temperzone's Split Systems Installation Guide** (refer www.temperzone.biz/Technical Support). Refer also to *Oil Charge* overleaf.

Maximum line length when extended is 60m.


Height Separation Limits

Outdoor Unit above Indoor Unit : 20 m
Outdoor Unit below Indoor Unit : 20 m

Dimensions (mm)




OSA 156RK



Not to Scale

Net Weight 116 kg



Vertical Risers

If the outdoor unit is to be installed above the indoor unit, then the suction riser should be trapped at the bottom of the vertical rise and then again at 8 m (maximum) intervals. This is to ensure oil return to the compressor. The trap to be a 'swan neck' curve in the pipe, with no change in the pipe size.

Piping

1. Use clean sealed refrigeration grade piping and accessories designed specifically for R410A.
 2. Cut pipe with a pipe cutter ONLY.
 3. Use long radius bends (2x pipe dia.).
 4. Insulate the suction (gas) line and seal all insulation joints.
 5. Bi-flow type filter dryer may be fitted in the liquid line.
 6. Include a process point in the interconnecting pipework.
 7. Ensure open pipe ends are sealed until the final connection is made.
 8. Immediately before removing brazed pipe connection's seal, reduce holding charge between connection points and service valves to atmospheric pressure.
- Warning:** Failure to do so may cause injury.

* 600 min with optional Vertical Discharge Grille

Charging

The unit is supplied with 4.9 kg of refrigerant HFC-410A (R410A) which is sufficient for up to 10 m of pipework between the indoor and outdoor units. Add 60 g of HFC-410A per metre above 10 m. **Subtract 0.5 kg when connected to ISU 160.**

Procedure:

1. Evacuate Indoor Unit and interconnecting pipework to a pressure of 500 microns and hold for 15 mins.
2. Add refrigerant, if needed, via the Schraeder connection on the smaller of the Outdoor Unit's two service valves.
3. Open the service valve at the Outdoor Unit to allow refrigerant to flow throughout the system.
4. Leak check all brazed and fitted joints.

IMPORTANT :

Step 8 of the 'Start Up Procedure' requires you to check that the superheat on the suction line (where it enters the Outdoor Unit) is between 3°C – 5°C on cooling cycle with an indoor air temperature in the range 21° – 27°C and outdoor air temperature in the range 24° – 35°C. If the conditions of the day do not allow this, use the heating cycle or other heat source to raise the indoor air temperature to about 24°C. Return to cooling cycle and blank off the outdoor coil to raise the head pressure to 400 psig (2760 kPag). Alter charge up or down to establish correct superheat.

WARNING:

This unit is designed for use ONLY with the refrigerant HFC-410A. The use of other refrigerants is NOT authorised or approved by the manufacturer and may cause operational problems such as poor performance and efficiency, loss of capacity, degradation of materials and refrigerant leaks. **The use of flammable or explosive materials as a refrigerant creates the additional risks of fire and explosion which may result in property damage, personal injury or death.**

Oil Charge

For line lengths in excess of 30 m, Emkarate RL22CF polyolester oil (or similar) should be added to the refrigerant at the rate of 13 ml/m of suction piping. **Note:** Do not use mineral oil.

ELECTRICAL REQUIREMENTS

Electrical work must be done by a qualified electrician. The outdoor unit must be wired directly from a distribution board by means of a circuit breaker or H.R.C. fuse, and a mains isolator provided - preferably close to the Outdoor Unit.

Note: DO NOT USE REWIRABLE FUSES.

Standard units are suitable for use with thermostats with either manual Heat/Cool selection or automatic changeover subject to the contact ratings of the thermostats.

Refer to **temperzone** for recommended thermostats.

It is recommended electricians run a spare wire between Outdoor Unit and Indoor Unit in case 'Indoor Fan Off During De-Ice' becomes a requirement. Leave this spare wire unconnected until required. (Not required when using **temperzone** SAT Controller). Refer indoor unit's wiring diagram.

A 24 hour power supply is required to the unit. Disconnect the crankcase heater if the total line length is less than 8 m.

SYSTEM CHECK TESTS

1. Leave the remote switch in the off position and close the mains isolating switch.
A four hour delay period is required to allow the crankcase heater to drive any liquid refrigerant out of the compressor oil. Bypass the crankcase heater thermostat (CCHT) for this period only.
2. Check that all fan motors are free running.
3. Check that the thermostat is correctly wired to the unit and is set at the desired temperature.
4. Check that the air filters, if any, have been correctly installed.
5. Check any supply air diffuser dampers are open.

START UP PROCEDURE

Use the supplied Commissioning Sheet to help you complete the following procedure:

1. Switch on the unit after the four hour delay period for the crankcase heater has expired. Ensure the crankcase heater thermostat has been reconnected.
2. Check the supply voltage.
3. Measure the current draw on the compressor motor and on each fan motor. Check all readings against the specified values - particularly the indoor fan amps if the unit is installed in a free blow application.
4. Fit gauges and measure the suction and discharge pressures.
Important: Gauges must be designed specifically for use with R410A.
5. Test the operation of the high pressure safety control by switching off the outdoor unit's fan.
6. Test the operation of the reversing valve by running the unit in both the heating and cooling mode.
7. Check that the air flow over the outdoor unit's coil is adequate and that the fan is running smoothly.
8. Check the superheat - refer charging procedure.
9. Check the supply air flow at each outlet.
10. Touch up any outdoor unit paintwork damage to prevent corrosion.

OUTDOOR UNIT CONTROLLER (OUC)

The Outdoor Unit Controller (OUC) includes a temperature sensing head pressure control which enables the system to compensate for outdoor ambient temperatures below 20°C, and heating cycle above 15°C. The OUC also has features which protect against icing or overheating of coils, rapid cycling of the compressor and loss of refrigerant charge.

If the outdoor unit fans take some time to begin rotating when the system is powered on, or they don't appear to be rotating appropriately while the compressor is running, consult the OUC label on the electrical box. If necessary, refer to **temperzone** for further diagnostic information.

MAINTENANCE

Weekly For First Four Weeks

1. Check indoor unit air filters (if fitted) and vacuum or wash clean as necessary.
2. Check condensate drain for free drainage.
3. Check compressor compartment for oil stains indicating refrigerant leaks.
4. Check tightness of electrical connections.

Six Monthly

1. Check the tightness of all fan and motor mountings.
2. Check tightness of electrical connections.
3. Check that fan motors are free running.
4. Check suction and discharge operating pressures.
5. Replace indoor unit air filters (if fitted).
6. Check condensate drain for free drainage.

Yearly

1. Check all refrigerant piping for chafing and vibration.
2. Check the operation of electric heaters if fitted.
3. Check air supply at all diffusers.
4. Check for excessive noise and vibration and correct as necessary.
5. Check for insulation and duct damage and repair as necessary.
6. Remove lint and dust accumulation from outdoor coil fins.
7. Touch up any outdoor unit paintwork damage to prevent corrosion.

NOTE

The manufacturer reserves the right to change specifications at any time without notice or obligation. Certified dimensions available on request.

This pamphlet replaces the previous issue no. 3495 dated 10/10.
Wiring revisions A.

Pipe Length Capacity Loss

On Cooling Cycle Due to Pressure Drop

Note : Loss percentages are approximations only, due to piping variations. No allowance made for vertical piping.

Pipe Size (mm)		Equivalent Line Pipe Length (m)					Additional Pipe Length to allow per Bend	
Liquid	Suction	5	10	15	20	30	Suction Pipe Size OD	22 mm
13	22	0.7 %	2.1 %	3.4 %	4.7 %	6.1 %	Long 90° Radius (2 x pipe dia.)	0.5 m

OUTDOOR UNIT :- OSA_156RKS
 WITH INDOOR UNIT
 CAPACITIES - NET to AS/NZS 3823
 COOLING - kW 14.95 15.04
 HEATING - REVERSE CYCLE kW 14.80 14.6
 ELECTRICAL INPUT
 COOLING - kW 4.90 4.855
 HEATING - REVERSE CYCLE kW 3.88 4.29
 E.E.R. (COOLING) kW/kw 3.05 3.098

SUPPLY REQUIRED 1PH 200-252V ~ 50Hz INCLUDING VOLTAGE FLUCTUATION LIMITS	
COMPRESSOR (1PH) RUN_AMPS RATED CONDITIONS	A 20.2 20
COMPRESSOR (1PH) STARTING AMPS	A 40 40
COMPRESSOR CAPACITOR RUN	MFD 50 50
COMPRESSOR CAPACITOR START	MFD 189-227 189-227
INDOOR FAN MOTOR (1PH) FULL LOAD AMPS	A 3.5 1.42x2
INDOOR FAN MOTOR CAPACITOR	MFD 15 5x2
OUTDOOR FAN MOTOR (1PH) FULL LOAD AMPS	A 0.94 0.94
OUTDOOR FAN MOTOR CAPACITOR	MFD 5 5
RUNNING AMPS (TOTAL)	A 25 23
RECOMMENDED EXTERNAL FUSE SIZE	A 45 45
WEIGHT - NETT OSA 156RKS	116 kg
REFRIGERANT - R410A	
COMPRESSOR - SCROLL	

COMPRESSOR OIL - P.O.E ; FOR LINE LENGTHS IN EXCESS OF 40m, ADD OIL AT THE RATE OF 13 ml/m OF SUCTION PIPE.
 UNIT PRECHARGED (10 METRE LINE LENGTH) 4.9 kg Subtract 0.5 Kg for ISU 160
 BASE CHARGE UNIT 4.3 kg PLUS 60 grams PER METRE LINE LENGTH
 BASED ON ø13 mm OD LIQUID LINE & ø22 mm OD GAS LINE


Sensor Locations	
CAP	CAPACITOR
CB	CIRCUIT BREAKER
CCH	CRANK CASE HEATER
CCHT	CRANK CASE HEATER T/STAT
CM	COMPRESSOR MOTOR
CMC	COMPRESSOR CONTACTOR
HP	HI PRESSURE CONTROL
LP	LOW PRESSURE CONTROL
OFM	OUTDOOR FAN MOTOR
OLC	OUTDOOR UNIT CONTROLLER
RV	REVERSING VALVE
SR	START RELAY

Title
 OSA 156RKSH
 WIRING SCHEMATIC



temperzone

Drawn J.S.L	Date 10-10-10	Drawing No. 526-244-002	Revision A
Scale	As'd		



CLIENT WIRING -----
 Interconnections between units by client. Double insulated multi-core cable.

ISSUE	MODIFICATION	ECN	DATE	APRVD.	DRG SIZE	No.	DESCRIPTION
A	T/STAT ADDED		10/27/21				

Programmed by

PLOTTED
 21-01-11
 ©temperzone ltd
 2004

OUTDOOR UNIT :- OSA 156RKT
 WITH INDOOR UNIT
 CAPACITIES - NET to AS/NZS 3823

COOLING -	kW	14.95	ISD 156	ISU 160
HEATING - REVERSE CYCLE	kW	14.80		
ELECTRICAL INPUT @ 3PH 400V ~ 50Hz				
COOLING -	kW	4.90		4.855
HEATING - REVERSE CYCLE	kW	3.88		4.29
E.E.R. (COOLING)	kW/kW	3.05		3.098


SUPPLY REQUIRED 3PH 342-436V ~ 50Hz INCLUDING VOLTAGE FLUCTUATION LIMITS

COMPRESSOR (3PH) RUN AMPS RATED CONDITIONS	A	7.1/PH	7/PH
INDOOR FAN MOTOR (1PH) FULL LOAD AMPS	A	3.5	1.42x2
INDOOR FAN MOTOR CAPACITOR	MFD	15	5x2
OUTDOOR FAN MOTOR (1PH) FULL LOAD AMPS	A	0.94	0.94
OUTDOOR FAN MOTOR CAPACITOR	MFD	5	5
RUNNING AMPS (TOTAL)	A	12/8/8	10.5/8/8
RECOMMENDED EXTERNAL FUSE SIZE	A	25	25

WEIGHT - NETT OSA 156RKT 116Kg
 REFRIGERANT - R410A
 UNIT RECHARGED (10 METRE LINE LENGTH) 4.9 Kg Subtract 0.5 Kg for ISU 160
 BASE CHARGE UNIT 4.3 Kg PLUS 60 grams PER METRE LINE LENGTH
 BASED ON Ø13 OD LIQUID LINE & Ø22 OD GAS LINE

COMPRESSOR TYPE: SCROLL
 OIL TYPE: POLYOLESTER (POE)
 ADD ADDITIONAL OIL 1.3ml PER METRE OVER 40 METRE LINE LENGTH

ABB	DESCRIPTION
CAP	CAPACITOR
CB	CIRCUIT BREAKER
CCH	CRANK CASE HEATER
CCHT	CRANK CASE HEATER T/STAT
CM	COMPRESSOR MOTOR
CMC	COMPRESSOR CONTACTOR
HP	HI PRESSURE CONTROL
LP	LOW PRESSURE CONTROL
OUC	OUTDOOR UNIT CONTROLLER
OFM	OUTDOOR FAN MOTOR
RV	REVERSING VALVE



Consult Outdoor Unit Controller label for further details, or refer to Temperzone for fault diagnosis information.
 Sensor Locations:
 Red to service valve pipe pocket.
 Yellow to coil return bend pocket.
 Blue to bottom of coil in fins.

CHECK WIRING BEFORE SWITCHING ON, INCORRECT CONNECTION WILL DAMAGE MOTORS

CLIENT WIRING - - - - -
 Interconnections between units by client. Double insulated multi-core cable.

Programmed by										
Plotted	21-01-11									
©temperzone ltd	2003									
ISSUE	MODIFICATION	ECN	DATE	APRVD	DRG SIZE	No.	DESCRIPTION	Mat.1	FINISH	ASSY No.
A	T/STAT ADDED		21/01/11	ROD						