

**File Name:** Air\_Handling\_Unit-Fan\_Coil-Temperzone-IXDL\_90Y(configuration)\_140203.01.rfa

**1 Family Type:** IXDL 90Y

**Modified Issue:** 140203.01

---

This read me document is provided for the purpose of parameter clarification. The temperzone product range is diverse and each group of units require unique parameters within their Revit Family to help define them. Parameters you may need help understanding are discussed below.

## Graphics Properties

The 'Graphics' instance parameter tick boxes, displayed within this family, are not a list of all the options available for this product. The purpose of these tick boxes is for the correct display of the products external geometry when any combination of specific options have been selected, and also to ensure the correct placement and sizing of connectors where applicable, therefore understanding these variations is important. If an available option for this product does not appear within the 'Graphics' properties list e.g. Electric Heat or Filters, then its inclusion does not effect the overall external geometry of the unit or its connectors.

The following are explanations for each of the 'Graphics' properties tick boxes within this family:

### Left Hand

Tick this box when the unit is a left hand model.

### Right Hand

'Right Hand' is **automatically ticked** when 'Left Hand' is not ticked.

### Filter Installed \_ Back Access

Tick this box when you have a standard filter installed and plan to have back access to remove the filter.

### Filter Installed \_ Right Access

Tick this box when you have a standard filter installed and plan to have right hand access to remove the filter.

### Filter Installed \_ Left Access

Tick this box when you have a standard filter installed and plan to have left hand access to remove the filter.

### Spigot Fan 1 Left Facing

Tick this box when your unit will be installed with Fan 1 supply air spigot facing left. When unticked Fan 1 supply air spigot will be forward facing.

### Spigot Fan 2 Right Facing

Tick this box when your unit will be installed with Fan 2 supply air spigot facing right. When unticked Fan 1 supply air spigot will be forward facing.

## Mounting Points

These are the four circular holes on the top of the unit.

## Connector Element Properties

Care has been taken to provide connector elements that are functional. Within this family you will find instance parameters, mapped to connectors, have been set to zero to allow for end user input. It is the end users responsibility to enter accurate data, for individual products, as required, into these fields. This data can be found within temperzone's technical data manuals or unit selection programmes. Visit [www.temperzone.biz](http://www.temperzone.biz) or contact your Temperzone representative for access to this information.

**AUCKLAND**

temperzone Ltd  
38 Tidal Road,  
Mangere South, Manukau 2022.  
Private Bag 93303,  
Otahuhu, Manukau 1640.  
Phone 0-9-279 5250  
Fax 0-9-275 5637  
Email sales@temperzone.co.nz

**WELLINGTON**

Phone 0-4-569 3262  
Fax 0-4-566 6249

**CHRISTCHURCH**

Phone 0-3-379 3216  
Fax 0-3-379 5956

**SINGAPORE**

temperzone Ltd  
1 Claymore Drive #08-13  
Rear Block, Orchard Towers  
Singapore 229594  
Phone SNG 6733 - 4292  
Fax SNG 6235 - 7180  
Email sales@temperzone.com.sg

**SYDNEY**

temperzone australia pty ltd  
14 Carnagie Pl, Blacktown, NSW 2148  
PO Box 8064, Seven Hills West NSW 2147  
Phone (02) 8822 - 5700  
Fax (02) 8822 - 5711  
Email sales@temperzone.com.au

**MELBOURNE**

Phone (03) 8769 - 7600  
Fax (03) 8769 - 7601

**ADELAIDE**

Phone (08) 8340 - 0607  
Fax (08) 8340 - 2118

**PERTH**

Phone (08) 9314 - 3844  
Fax (08) 9314 - 3855

**TOWNSVILLE**

Phone (07) 4773 - 9566  
Fax (07) 4773 - 9166

**BRISBANE**

Phone (07) 3308 - 8333  
Fax (07) 3308 - 8330

**NEWCASTLE**

Phone (02) 4962 - 1155  
Fax (02) 4961 - 5101

**HOBART**

Phone (03) 6331 - 4209  
Fax (03) 6333 - 0224

*Visit our website [www.temperzone.biz](http://www.temperzone.biz)*